



No.DJB/QCLTYR/PD/250306

DELHI JAL BOARD
 (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION
TAHIRPUR DELHI-110093

ACWA-TYR

Diary No. 192 dt. 07.04.2025



NO: DJB/ACWA(TYR)/2025.....

DATE:- 28-03-2025

Analysis report of DJB water Supply samples collected from (1) Inlet, (2) Outlet of M/S SAAI MEMORIAL GIRLS SCHOOL, SAI BHAWAN, GEETA COLONY, DELHI-110031 for drinking purpose.

Ref. No. NIL

Challan No: - 283,

dated: - 17.03.2025

Date of collection : 26-03-2025

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A. Physical Examination						
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	1.96	2.14
4.	pH Value	6.5-8.5	--	-	7.5	7.6
5.	Electrical Conductivity	--	--	µs/cm	208	186
6.	Total Dissolved Solids	500	2000	mg/l	135	121
B. Chemical Examination						
7.	P th Alkalinity	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	66	64
9.	Total Hardness	200	600	mg/l	80	82
10.	Calcium as (Ca)	75	200	mg/l	25.6	24.8
11.	Magnesium as (Mg)	30	100	mg/l	3.84	4.80
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	1.46	1.52
15.	Sulphate	200	400	mg/l	27.61	27.86
16.	Chloride	250	1000	mg/l	10	08
17.	Fluoride	1.0	1.5	mg/l	0.05	0.04
18.	Total Iron	1.0	NR	mg/l	0.07	0.08
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.75	0.60
C. Bacteriological Examination						
21.	Coliform count	Absent	NR	MPN/100ml	0	0

This Reporting Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

(Signature)
29/3/25

(B.K Verma)
Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93

(Signature)
28-3-25

(A.G Susmitha)
BACTERIOLOGIST

(Signature)
29/3/2025

(Gulesh Jainar)
CHEMIST

(Signature)
28.03.2025

(Mayank Yadav)
A/CHEMIST

SAAI MEMORIAL GIRLS SCHOOL
SAI BHAWAN

(Recognised & Affiliated to C.B.S.E.)
(An English Medium School for Girls)
Geeta Colony, Near Petrol Pump,

(Signature)
N. Keswani

(Signature)
Principal
SAAI MEMORIAL GIRLS SCHOOL
SAI BHAWAN
(Recognised & Affiliated to C.B.S.E.)
(An English Medium School for Girls)
Geeta Colony, Near Petrol Pump,
Delhi-110031



Municipal Corporation of Delhi
PUBLIC HEALTH DEPARTMENT
SHAHDARA (SOUTH) ZONE
419, UDYOG SADAN, PATPARGANJ
INDUSTRIAL AREA, DELHI - 92



No. DHO/Shd.(S)/2025/D-1368

Dated:- 17/10/25

SCHOOL HEALTH CERTIFICATE

01- Name of the School	: Saai Memorial Girls School
02- Location of the School	: Sai Bhawan, Geeta Colony, Delhi-110031
03- Timing of the School	: 7:45 AM to 01:45 PM
04- No. of Students	: 1594
05- No. of Doors in each rooms	: Provided In Each Room
06- No. Of fans in each rooms	: Provided in Each Room
07- Building Structure	: Pucca
08- Electricity	: BSES
09- Water Supply	: DJB
10- No. of Toilets for Girls	: 21
11- No. of Staff	: 75


At the time of inspection, School is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal

Saai Memorial Girls School
Sai Bhawan, Geeta Colony, Delhi-110051

[Signature]
Deputy Health Officer
Shahdara South Zone



N. Kerwan
CHAIRPERSON
SAAI MEMORIAL GIRLS SCHOOL
SAI BHAWAN
(Recognised & Affiliated to C.B.S.E)
(An English Medium School for Girls)
Geeta Colony, Near Petrol Pump,
Delhi-110031

Alenway
Principal
SAAI MEMORIAL GIRLS SCHOOL
SAI BHAWAN
(Recognised & Affiliated to C.B.S.E)
(An English Medium School for Girls)
Geeta Colony, Near Petrol Pump,
Delhi-110031